

AMENDMENT OF SOLICITATION

1. AMENDMENT NO. 02	2. EFFECTIVE DATE – 10/17/2024	3. PAGE 1 of 2
---------------------	--------------------------------	----------------

4. ISSUED BY: **Fluor-BWXT Portsmouth LLC**
P.O. Box 548
3930 US Route 23 South
Piketon, OH 45661

5. NAME AND ADDRESS OF CONTRACTOR (<i>Name, street, county, state & zip code</i>)	6. AMENDMENT OF (RFP) SOLICITATION NO. FBP25SC200051	DATE
All Offeror(s)		10/3/2024

7.
 The above numbered solicitation is amended as set forth in Item 8. The hour and date specified for receipt of Offers is extended X is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods:

(a) By completing Items 5 and 9, and returning one (1) copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or e-mail which includes a reference to the solicitation and amendment numbers. **FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.** If by virtue of this amendment you desire to change an offer already submitted, such change may be made by e-mail or letter, provided each e-mail or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

8. DESCRIPTION OF AMENDMENT

Except as provided herein, all terms and conditions of the document remain unchanged and in full force and effect.

Add the following to the aforementioned Request for Proposal:

1. Questions and Answers Rev 0 10/17/2024

9A. NAME AND TITLE OF SIGNER (<i>Type or print</i>)	10A. Fluor BWXT Portsmouth LLC Kelli Bunstine – Contract Administrator		
9B. CONTRACTOR/OFFEROR	9C. DATE SIGNED	10B.	10C. DATE SIGNED
_____ (<i>Signature of person authorized to sign</i>)		_____ (<i>Signature</i>)	10/17/2024

Solicitation No.		
Question #	RFP Reference Text:	
1	2.3	The Company will provide the contractor with a source of structural fill as needed.
	Civil	Who is loading/delivering structural fill to site.
2	2.5	Describes building being provided.
	Metal Building	Will there be a manufacturers rep available to consult with during assembly? How far will the building and parts be staged from the construction site, and who is doing inventory when the building is received?
3	2.9	Smartnet for Switch.
	Communications	Smartnet seems to be a warranty through Cisco, Please describe what expectation is for the Smartnet for Switch?
4	2.6	List of Additional Material.
	Architectural (By Others)	Are these materials listed being provided by the company?
5	2.11	Office size shown on drawings.
	Office	Is there a design drawing for the offices?
6		
7		
8		
9		
10		
11		
12		

FBP will provide and deliver structural fill to job site.

No. The building and parts will be staged within a 1/4 mile from the job site. FBP will receive and inventory the building and parts. FBP will turnover the building and parts to the contractor so they can receive and inventory the building and parts.

Smartnet line item is no longer required when purchasing a Cisco switch – it was the service plan for maintenance/replacement but Cisco has changed their program to cover the “enterprise” using the switch, not each switch individually.

FBP will provide the first seven bullets under 2.6 Architectual. The materials for the office space will need to be procured by the contractor.

No. The design will be on the contractor to submit for approval.